

## ***India-Japan International Collaboration for an Innovative Sewage Treatment Technology with Cost-effective and Minimum Energy Requirement***

---

**Hideki HARADA**


*Dept. of Civil & Environ. Eng., Tohoku University, Japan  
Previously Nagaoka Univ. of Technology*



Asian Science and Technology Seminar (ASTS) in Thailand, 9-11 March, 2008

### **The Content of My Talk**

- 1 Watching water pollution of the GANGA Basin**
- 2 International Collaboration Project with India for UASB/DHS™ system as a low-cost STT**  
DHS stands for **D**own-flow **H**anging **S**ponge Reactor
- 3 Evolution of DHS Technology**
- 4 UASB/DHS system is the best option—Toward World Standard for Appropriate STT**





Scene 3: Delhi, India




Scene 3: Delhi, India




Scene 4: Delhi, India

**Urban Drainage flows into the Yamuna without treatment**




### Pollution of the YAMUNA RIVER, DO and BOD





**DO > 5mg/L**

**Water Quality Standard for Bathing**



**BOD < 3mg/L**



## From GAP to YAP, from ASP to UASB






Type of Treatment Systems	GAP-1 No. of Plants constructed	YAP No. of Plants constructed
Activated Sludge Process (ASP)	17 →	0
(Stabilization Pond) Oxidation Pond (OP)	14	9
Upflow Anaerobic Sludge Blanket (UASB)	3 →	16




Abandoned Activated Sludge Plant













## Indian existing system




## Karnal STP layout

40 MLD Capacity



## UASB + FPU Performance




BOD (mg/L)	Sewage	UASB eff.	FPU eff.	BODt. rem. (%)
Panipat 35MLD	196	131	116	41
Faridabad 45MLD	318	111	98	69
Faridabad 50MLD	365	179	154	58
Gurgaon 30MLD	318	154	104	67
Ghaziabad 70MLD	293	151	85	71
Agra 78MLD	264	126	64	76

Harada et al (2005), Jour. of Environ. Management



## Our proposed system



## Combination of UASB and DHS

## Proposed system

- (1) Low-cost, (4) Energy Thrifty,
- (2) Simple, (5) Easy O & M,
- (3) compact, (6) techno-economically feasible



(Down-flow Hanging Sponge- reactor)



Visit of Indian Government Delegation to Nagaoka, Feb. 2002







**1000 m<sup>3</sup>/d Demonstration Scale DHS Biotower in Karnal, India**  
**Constructed by Indian Government, under Yamuna Action Plan (YAP)**



**DHS Biotower**




**Wastewater distributor**

**HRT: 1.5h**



**Sponge curtains inside the biotower**



**Sending Graduate-students to Karnal STP site since Oct. 2002**




**Fuel is, of course, cow-dung**




**Put into curry-pot**






### Overall Summary Result of 5-ys non-stop operation







## Time course of temperature and DO




## Time course of BOD



## Time course of COD



## Time course of Fecal coliforms



## Summary

	Raw sewage influent	UASB effluent	DHS effluent	Polishing pond effluent
	average	average	average	average
pH	7.20 (0.17)	7.04 (0.14)	7.87 (0.15)	7.32 (0.28)
DO, mg/L	-	-	5.2 (1.1)	0.5 (1.6)
BOD-total, mg/L	151 (48)	56 (19)	6 (4)	44 (16)
COD <sub>cr</sub> -total, mg/L	430 (129)	177 (44)	30 (13)	143 (41)
COD <sub>cr</sub> -soluble, mg/L	143 (45)	86 (20)	19 (10)	64 (22)
Fecal coli., MPN/100mL	7.71 x 10 <sup>6</sup>	4.87 x 10 <sup>6</sup>	9.80 x 10 <sup>1</sup>	6.81 x 10 <sup>1</sup>
NH <sub>4</sub> -N, mg/L	25 (7)	26 (8)	6 (5)	25 (9)
NO <sub>3</sub> -N, mg/L	ND	ND	5 (3)	ND
SS, mg/L	228 (91)	53 (20)	13 (5)	48 (26)
Temperature, °C	15-33			
Flow rate, MLD	26.3			
Removal		UASB	UASB + DHS	UASB + FPU
BOD-total, %		63 (13)	96 (3)	69 (13)
COD <sub>cr</sub> -total, %		58 (14)	94 (4)	64 (15)
Fecal coli., log <sub>10</sub>		0.2	1.9	1.0
NH <sub>4</sub> -N, %			79 (15)	9 (25)
SS, %		74 (12)	93 (6)	75 (23)


### General Advantages of DHS post-treatment System

- No need of External Aeration, much less energy requirement
- No clogging, no back-washing, no laborious maintenance
- Much less amount of Excess Sludge
- Less Area Requirement
- High Performance at equivalent HRT to Activated Sludge Process







## Retained Sludge in DHS Sponge



Average retained sludge in the reactor:  
**26 gm-VSS/lit. of sponge vol.**  
 Calculated SRT:  
**76 days.**  
 Negligible amount of excess sludge




SEM images of clean sponge




SEM images of entrapped sludge







## DHS concept




## Evolution of DHS Process




## Process Performance of DHS variants in Nagaoka


	 DHS G1	 DHS G2	 DHS G5	 DHS G3	 DHS G4	 DHS G6
HRT (h)	2.3	2	2.5	2.7	2	2
BOD removal(%)	97	96	95	98	96	96
COD removal(%)	94	84	90	93	91	93
SS removal(%)	98	68	95	92	93	95
NH4-N removal(%)	75	64	60	86	28	75
F. coli removal (log 10)	-	2.7	4.0	2.6	3.5	2.8
SRT (d)	-	90~100	90~125	-	100~125	~100
Sponge occupancy(%)	-	25	55~57	38	38	34



### BOD removal by Activated Sludge process throughout Japan




## BOD removal by (UASB+DHS) system (Karnal, India)



## Power consumption for sewage treatment

	Total power consumption	Pumping	Water treatment	Sludge treatment	Others
Total; $\times 10^3$ kWh/yr	5,956,000	896,000	2,913,000	1,359,000	739,000
Percentage	100.0	15.0	48.9	22.8	12.4
per WW amount treated; kWh/m <sup>3</sup>	0.46	0.07	0.22	0.1	0.06
per capita; kWh/capita/yr	73.5	Amount of treated water; m <sup>3</sup>		13,019,790,000	
		Population; capital		81,076,000	

Power consumption per amount of sewage; **0.46 kWh/m<sup>3</sup>**  
 Statistic of Japan Sewage Works, 2001





### How much power should be required for Sewage Treatment, if Activated Sludge Process is employed?

Per capita Annual Sewage Amount =  $175 \text{ liter day}^{-1} = 63.4 \text{ m}^3 \text{ capita}^{-1} \text{ yr}^{-1}$

Per capita Annual Power Requirement for Sewage Treatment =  $63.4 \text{ m}^3 \text{ capita}^{-1} \text{ yr}^{-1} \times 0.46 \text{ kWh m}^{-3} = 29.2 \text{ kWh capita}^{-1} \text{ yr}^{-1}$

Country	Annual Power Consumption (kWh/capita-year)	Annual Power Requirement for Sewage Treatment (Per Capita)
		Annual Power Consumption (%)
Nepal	66	44.0
Bangladesh	103	28.3
Myanmar	130	21.7
Laos	140	20.9
Sri Lanka	301	9.7
Vietnam	333	8.8
Indonesia	379	7.7
Pakistan	413	7.1
India	473	6.2
Philippines	497	5.9
Columbia	954	3.1
Mexico	1778	1.6
Brazil	1846	1.6
World	2206	1.3
Japan	7230	0.4
UAE	14153	0.2

CIA World Fact Book (2003)

## Conclusive Remarks

1. Our Proposed UASB-DHS combined system exhibited an excellent performance, producing Effluent BOD less than 10 mg/L with a HRT of only 8 h (UASB 6 h and DHS 2h) that is equivalent to that of conventional ASP.
2. The UASB-DHS combined system requires
  - no external forced aeration,
  - no laborious maintenance,
  - less sludge production,
  - less land area,
  - resulting in reducing running cost into only 1/5-1/10 of conventional ASP.
3. The UASB-DHS combined system may offer the best option for low-cost and low-energy treatment of municipal wastewater under tropical/sub-tropical climate.

