

Energy savings potential in the commercial sector

June 2011

Center for Low Carbon Society Strategy

Contents

- Estimation of the load curve of the commercial sector for a summer day
- Sensitivity analysis: Variation in demand with outdoor temperature and air conditioning COP
- Evaluation of effects from measures

Estimation of electricity demand

- Estimation of daily load curve for the commercial sector in TEPCO service area
 - Include Tokyo, Kanagawa, Saitama, Chiba, Ibaraki, Tochigi, Gunma, Yamanashi, parts of Shizuoka
 - Average hourly electricity demand in July, August and September
 - Industries considered
 - Schools
 - K-12 schools, Universities
 - Hotels
 - “City hotels” and “business hotels”
 - Exclude “ryokan” hotels
 - Hospitals and elderly care facilities
 - Exclude clinics and dentists
 - Food and services
 - “Family restaurants”, fast food, “soba” and “udon”, Japanese and Chinese restaurants
 - Fitness clubs, karaoke houses
- Air conditioning settings
 - COP of electric air conditioning : 2.5
 - Ratio of gas air conditioning : 25%

Base data for estimation

- Number of offices
 - By industry, by prefecture
 - Source : Economy census¹
- Floor area per office
 - By industry
 - Source: investigated a sample of few ten offices per industry
- Air conditioning and general electricity demand
 - By industry
 - Source: investigated a sample of few ten offices per industry
- Demand by month, by hour in one day
 - By industry
 - Source : The society of heating, air conditioning and sanitary engineers of Japan², Ojima research group³, Agency for Natural Resources and Energy⁴, measured data⁵



Consistency check

	2pm demand (10,000kW)		Gloss floor area (10,000m ²)	
	This estimate	ANRE	This estimate	ANRE
Hospitals	207	160	3028	3000
Hotels	165	120	3129	2250
Restaurants	99※ ¹	190※ ¹	1033	2300
Schoos※ ²	86	130	11520	9060

※¹ 8pm demand

※² Elementary, middle, and high schools only


Total demand




Peak demand : 7.5 million kW

Covers about 1/3 of peak demand in the commercial sector (25 million kW)


By industry (schools)




By industry (hotels)




By industry (hospitals)




By industry (fitness/karaoke)



By industry (restaurants)




Variation of demand with temperature



About 3% change with change of 1°C → Increase air conditioning setting temperature by 1°C reduces electricity demand by 3%

Variation of demand with COP




Improvement from COP2.5 to 3.0 reduces demand by about 5%

Measures taken

	Restaurants	Sports clubs	Karaoke houses
Lighting	<ul style="list-style-type: none"> •Turn off backyard lighting when no one is using •Revise lighting on/off rules for billboards, outside lighting, parking lots •Revise lighting on/off rules for customer seats during stand-by before opening 	<ul style="list-style-type: none"> •Revise lighting on/off rules during cleaning •Reduction of lights based on brightness •Turn off backyard lighting when no one is using •Revise lighting on/off rules for outside lighting •Replacement of conventional light bulbs with LED lighting 	<ul style="list-style-type: none"> •Turn off backyard lighting when no one is using •Revise lighting on/off rules for billboards, outside lighting, parking lots •Revise lighting on/off rules for customer seats during stand-by before opening •Reduction of lights based on brightness •Replacement of conventional light bulbs with LED lighting
Air conditioning	<ul style="list-style-type: none"> •Revise on/off rules for air conditioners •Change temperature settings by area •Change temperature settings by time (by number of guests and external temperature) •Use external air in mornings and evenings to reduce air conditioning load 	<ul style="list-style-type: none"> •Revise on/off rules during operating hours •Revise on/off rules outside operating hours •Change temperature settings •Revise backyard air conditioning usage rules 	<ul style="list-style-type: none"> •Revise on/off rules for air conditioners by area •Change temperature settings by area •Revise on/off rules for air conditioners during stand-by and closing
	Periodically clean filters (about once every two weeks)	Periodically clean filters (about once every two weeks)	Periodically clean filters (about once every two weeks)
	Use window shades, heat shield film, hoods, screens		
Kitchen appliances	<ul style="list-style-type: none"> •Do not leave refrigerator and fridge door open •Quickly store or remove food 		<ul style="list-style-type: none"> •Do not leave refrigerator and fridge door open •Quickly store or remove food
	<ul style="list-style-type: none"> •Revise temperature settings of kitchen appliances •Revise on/off rules •Adjust number of operating appliances based on number of guests 		<ul style="list-style-type: none"> •Revise temperature settings of kitchen appliances •Revise on/off rules •Adjust number of operating appliances based on number of guests
	<ul style="list-style-type: none"> •Do not leave refrigerator and fridge door open while storing or removing food •Turn off internal lighting unless while storing or removing food •Quickly store or remove food 		
Power outlets		<ul style="list-style-type: none"> •During closing, remove power cables of electric appliances that will not be used 	
Others		<ul style="list-style-type: none"> •Revise on/off rules of hot water related pumps •Reduce operating air supply and exhaust system equipment 	

Evaluation of implemented measures




Scope of measures

- Restaurants : 10~15%
- Fitness clubs : 3~9%
- Karaoke houses : 10%

Measures taken

Measures were limited to those already taken in the past that can be implemented easily and in a short time (e.g. air conditioning)

⇒ Total power savings of about 90,000kW~140,000kW



Summary

- Estimated load curve for about 1/3 of demand out of the total 25 million kW of the commercial sector
- Implementing easy to implement measures in half of the stores in three industries (restaurants, fitness clubs, karaoke houses) results in at least 140,000kW of power savings
 - This power savings corresponds in all users of the 25 million kW commercial sector
 - Increasing the air conditioning temperature setting by about $0.5 \sim 1^{\circ}\text{C}$
 - Improving the COP by about $0.1 \sim 0.2$
(Corresponds to changing to air conditioning equipment that consumes 4% to 7% less electricity)
- Hospitals, hotels, schools
 - If 3% of power savings is possible, the combined 6 industries have the potential for power savings of about 320,000kW

References

1. Ministry of Internal Affairs and Communications: 2009 Economic Census – Basic Survey
2. The Society of Heating, Air-Conditioning and Sanitary Engineering of Japan: Standard load data
3. Ojima Group (Waseda University) : “Basic units of light, heating and water utilities in buildings”
4. Agency for Natural Resources and Energy : “Estimated electricity demand structure for a peak summer day peak (TEPCO service area)
<http://www.meti.go.jp/setsuden/20110513taisaku/16.pdf>
5. Data from PICO ADA Co.,Ltd.